



DECLARATION OF PERFORMANCE

Declaration of Performance No : 002300

1. Unique identification code of the product-type:

6242Y 2x6+2,5 mm² 300/500 V BS 6004

2. Type, batch or serial number or any other element allowing identification of the construction product.

Stranded Copper Conductor (Class 2), PVC Insulation, PVC Sheathed cable with circuit protective conductor (CPC).

3. Intended use of the product:

Cable to supply energy in buildings and other construction works subject to regulation on reaction to fire.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer.

HES KABLO (HES HACILAR ELEKTRİK SANAYİ ve TİCARET A.Ş.)

Erciyes Mah. Hes Cad. No:22 38210 KAYSERİ/TURKEY

Tel: 0352 207 45 00

Fax: 0352 207 45 20

E-mail: hes@hes.com.tr

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks.

-

6. System or systems of assessment and verification of constancy of performance of the construction product.

System 3

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Turkish Standard Institute (Notified Body No: 1783) has determined the product class under System 3 by means of performing related tests on cable samples.

8. Declared performance

Essential Characteristics Performance	Harmonized Technical Specification	Reference No of Technical Doc.
Reaction to fire : Eca	EN 50575:2014	1783 - CPR - 447647
Dangerous substance : NPD	EN 50575/A1: 2016	

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued, in accordance with Construction Products Regulation (305/2011/EU), under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

İbrahim GÜVEN

Quality Control & Management System Manager

KAYSERİ/TÜRKİYE

28.12.2018



PERFORMANS BEYANI

Performans Beyan No:

002300

1. Ürün tipi kimlik kodu:

6242Y 2x6+2,5 mm² 300/500 V BS 6004

2. Yapı malzemesinin tip, parti veya seri numarası ya da tanımlanmasını sağlayacak diğer unsurlar:

Örgülü Bakır İletken (Sınıf 2), PVC Yalıtım, PVC Kılıflı, Devre Koruyucu İletkene Sahip Kablo (DKİ).

3. Ürünün kullanım alanı:

Binalara ve diğer yapılara enerji sağlayan bu kablolar, yangına tepki düzenlemesine tabi olarak çalışır.

4. İmalâtçının adı, tescilli ticarî unvanı veya tescilli markası ile adresi:

HES KABLO (HES HACILAR ELEKTRİK SANAYİ ve TİCARET A.Ş.)

Erciyes Mah. Hes Cad. No:22 38210 KAYSERİ/TURKEY

Tel: 0352 207 45 00

Fax: 0352 207 45 20

E-posta: hes@hes.com.tr

5. Mevcut ise, yetkili temsilcinin adı ve adresi:

-

6. Yapı malzemesinin performansının değişmezliğinin değerlendirilmesi ve doğrulanması sistem veya sistemleri:

Sistem 3

7. Uyumlaştırılmış bir standart kapsamında olan bir yapı malzemesine ilişkin performans beyanında:

Türk Standartları Enstitüsü TSE (Onaylanmış Kuruluş No.: 1783) tarafından,

Sistem 3 altında kablo

numunelerinin testleri gerçekleştirilmiş ve ürün sınıfı belirlenmiştir.

8. Beyan edilen performans

Temel Özellikler	Uyumlu Teknik Özellikler	Teknik Belge Referans No
Yangına Tepki Sınıfı : Eca	EN 50575:2014	1783 - CPR - 447647
Tehlikeli Maddeler : Performans Beyan Edilmemiştir.	EN 50575/A1: 2016	

9. Bu performans beyanının birinci ve ikinci maddelerinde tanımlanan yapı malzemesi, bu performans beyanının sekizinci maddesinde beyan edilen performansa sahiptir. Yapı Malzemeleri Yönetmeliği (305/2011/AB) uyarınca hazırlanan bu performans beyanı sadece yukarıda tanımlanan imalatçının sorumluluğu altında yayımlanır.

Üretici adına imzalayan:

İbrahim GÜVEN

Kalite Kontrol ve Yönetim Sistemleri Müdürü

HACILAR/KAYSERİ

28.12.2018