



## DECLARATION OF PERFORMANCE

### Declaration of Performance No : 000011

1. Unique identification code of the product-type:

**H07V-R 10 mm<sup>2</sup> 450/750 V EN 50525-2-31, BS EN 50525-2-31**

2. Type, batch or serial number or any other element allowing identification of the construction product.

**Stranded Copper Conductor (Class 2), PVC Insulation.**

3. Intended use of the product:

**Cable to supply energy in buildings and other construction works subject to regulation on reaction to fire.**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer.

**HES KABLO (HES HACILAR ELEKTRİK SANAYİ ve TİCARET A.Ş.)**

**Erciyes Mah. Hes Cad. No:22 38210 KAYSERİ/TURKEY**

**Tel: 0352 207 45 00**

**Fax: 0352 207 45 20**

**E-mail: hes@hes.com.tr**

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks.

-

6. System or systems of assessment and verification of constancy of performance of the construction product.

**System 3**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**Turkish Standard Institute (Notified Body No: 1783) has determined the product class under System 3 by means of performing related tests on cable samples.**

8. Declared performance

Essential Characteristics Performance	Harmonized Technical Specification	Reference No of Technical Doc.
Reaction to fire : Eca	EN 50575:2014	1783 - CPR - 335462
Dangerous substance : NPD	EN 50575/A1: 2016	

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued, in accordance with Construction Products Regulation (305/2011/EU), under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

**İbrahim GÜVEN**

**Quality Control & Management System Manager**

**KAYSERİ/TÜRKİYE**

**22.03.2017**



## PERFORMANS BEYANI

**Performans Beyan No:**

**000011**

1. Ürün tipi kimlik kodu:

**H07V-R 10 mm<sup>2</sup> 450/750 V EN 50525-2-31, BS EN 50525-2-31**

2. Yapı malzemesinin tip, parti veya seri numarası ya da tanımlanmasını sağlayacak diğer unsurlar:

**Örgülü Bakır İletken (Sınıf 2), PVC Yalıtım.**

3. Ürünün kullanım alanı:

**Binalara ve diğer yapılara enerji sağlayan bu kablolar, yangına tepki düzenlemesine tabi olarak çalışır.**

4. İmalâtçının adı, tescilli ticarî unvanı veya tescilli markası ile adresi:

**HES KABLO (HES HACILAR ELEKTRİK SANAYİ ve TİCARET A.Ş.)**

**Erciyes Mah. Hes Cad. No:22 38210 KAYSERİ/TURKEY**

**Tel: 0352 207 45 00**

**Fax: 0352 207 45 20**

**E-posta: hes@hes.com.tr**

5. Mevcut ise, yetkili temsilcinin adı ve adresi:

-

6. Yapı malzemesinin performansının değişmezliğinin değerlendirilmesi ve doğrulanması sistem veya sistemleri:

**Sistem 3**

7. Uyumlaştırılmış bir standart kapsamında olan bir yapı malzemesine ilişkin performans beyanında:

**Türk Standartları Enstitüsü TSE (Onaylanmış Kuruluş No.: 1783) tarafından,**

**Sistem 3 altında kablo**

**numunelerinin testleri gerçekleştirilmiş ve ürün sınıfı belirlenmiştir.**

8. Beyan edilen performans

Temel Özellikler	Uyumlu Teknik Özellikler	Teknik Belge Referans No
Yangına Tepki Sınıfı : Eca	EN 50575:2014	1783 - CPR - 335462
Tehlikeli Maddeler : Performans Beyan Edilmemiştir.	EN 50575/A1: 2016	

9. Bu performans beyanının birinci ve ikinci maddelerinde tanımlanan yapı malzemesi, bu performans beyanının sekizinci maddesinde beyan edilen performansa sahiptir. Yapı Malzemeleri Yönetmeliği (305/2011/AB) uyarınca hazırlanan bu performans beyanı sadece yukarıda tanımlanan imalatçının sorumluluğu altında yayımlanır.

Üretici adına imzalayan:

**İbrahim GÜVEN**

**Kalite Kontrol ve Yönetim Sistemleri Müdürü**

**HACILAR/KAYSERİ**

**22.03.2017**